



admin@mhcwd.org (530) 878-8096
16733 Placer Hills Road, P.O. Box 596, Meadow Vista, CA 95722

MWCWD Non-lead Statement

Midway Heights County Water District has completed the initial lead service line inventory required by U.S. EPA's Lead and Copper Rule Revisions. The deadline for the initial inventories is October 16, 2024.

Through completing a historical records review and field investigations, Midway Heights County Water District has determined it has no lead or galvanized requiring replacement service lines in its distribution system. This includes any privately-owned or customer-owned service lines.

Midway Heights County Water District reviewed all applicable sources of information, including

- All construction and plumbing codes, permits, and existing records or other documentation which indicates the service line materials;
- All water system records, including distribution system maps and drawings, historical records on each service connection, meter installation records, historical capital improvement or master plans, and standard operating procedures;
- All inspections and records of the distribution system that indicate service line material, including inspections conducted during the course of normal operations (e.g., checking service line materials when reading water meters, performing maintenance activities and annual backflow testing); and
- All previous meters have been replaced.

In addition to reviewing the above sources of information, Midway Heights County Water District physically inspected all service lines in its distribution system, regardless of ownership. All service lines were verified non-lead plastic.

Midway Heights County Water District will update service line material information obtained from normal operations, such as service line maintenance, installation, or water meter readings, after October 2024 and will update the initial inventory accordingly.